

#### AMERICA ATMO Sphere the Business Case natural refrigerants





Natural Refrigerant Heat Pump Technologies

#### Carbon Dioxide Heat Pump Field Study

Washington, DC June 18, 2013





- **1.** Introduction Merle Rocke, CEO, EcoThermics
- 2. Case Study Darin Massner, CEO, Country Maid
- 3. Q&A

# **EcoThermics Mission**



### Building a sustainable business -providing high value compressors for CO<sub>2</sub> heat pumps.



# **EcoThermics AT54M**











# Eco<sub>2</sub>Boost<sup>®</sup> Heat Pump (concept)





#### Eco<sub>2</sub>Boost<sup>®</sup> Installed at Country Maid





#### DOUBLE-CLICK IN BOX



#### 16" x 24" footprint

40" Tall

## Country Maid – West Bend, IA (Darin Massner, CEO)





Manufacturer of Butter Braid® brand products West Bend, IA

# **Country Maid Introduction**



- Founded in 1991
- **55,000** sq. ft.
- 80 employees
- 100% employee owned
- Frozen pastry dough products
- Sell products to dealer network in 46 states



# Dedicated CO2 Heat Recovery Heat Pump "The Eco<sub>2</sub>Boost®"

- Hot Water for Sanitation and
- Supplemental A/C & Dehumidification

## Serving Plant Production Areas

## **Base Conditions**



#### **PRE-EXISTING HOT WATER COST ESTIMATES**

Cost of Hot Water Energy Per Day -	\$43
PerYear -	\$10,000

# Consumption volume is expected to increase by and estimated 1200 gal./day (20%) in 2013...

2013-14 Forecast Cost of Hot Water Energy Per Day -	\$51
-----------------------------------------------------	------

#### 2013-14 Forecast Cost of Hot Water Energy Per Year - \$12,000

# **Retrofit Goals**



- Demonstrate the capability for simultaneous water heating and space conditioning with a CO2 heat pump
- Quantify energy and cost reductions





# **Significant Hot Water Requirements**





## **Need for Production Area Space Conditioning**



Simultaneous Space Conditioning

- Air Conditioning
- Dehumidification







- Heating COP = 3.8
- Cooling COP = 2.9
- Combined COP = 6.7
- NG Energy cost savings = \$3300/year
- Energy cost savings w/o electric = \$8000/year
- \* Using summer 2012 conditions and energy rates @ 2200 gal/day

# **Eco<sub>2</sub>Boost System Schematic**



**Shaft Power IN** 

# **System Operation "Before"**





#### Average Total Water Consumption:

~6000 gallons / day - \*No space conditioning

Sanitation & Process Use

## **Retrofit Summary "After"**





# **RESULTS - Data**



Volume target: 2000-2200 gallon per	day	Achieved
Target = >140°F - 145°F	145°F	Achieved
Target Heating COP = 3.8	4.2	Achieved
Target Cooling COP = 2.9	3.0	Achieved
Target Combined COP = 6.7	7.2	Achieved

# **RESULTS – Calculated Savings/Year**



- A/C ONLY \* NEGLIGIBLE SAVINGS/YEAR
- HEATING ONLY Eco HPWH vs NATURAL GAS ~\$1355/Yr
- HEATING ONLY Eco HPWH vs ELECTRIC ~\$6428/Yr
- HEATING ONLY Eco HPWH vs NG / Elec BASELINE ~\$2292/Yr
- SIMULTANEOUS HEAT/COOL vs NATURAL GAS ~\$3340/Yr
- SIMULTANEOUS HEAT/COOL vs ELECTRIC ~\$8412/Yr
- SIMULTANEOUS vs BASELINE (NG + ELECTRIC) ~\$4276/Yr

\*A/C Cost/year (EST. Country Maid Baseline) ~\$2184

# Summary



Transcritical CO2 Dedicated Heat Recovery for Primary Sanitation Hot Water & Simultaneous Supplemental A/C for Food Production & Packaging Areas with estimated BET < 4.0 years.

<u>Note:</u> Due to time limitations, this summary was very brief; Much more detailed data available upon request.





# **Thank You**



# Ecorporation

Contact us: Merle G. Rocke, CEO mrocke@ecothermics.com 309-303-0681 www.ecothermics.com