



June 18-19, 2013 in Washington DC





# How Different Condensers and Refrigerants Affect Total Refrigeration System Energy Consumption

Preston Blay

Ilana Cember

June 19, 2013

- Refrigeration system  $\approx 50\%$  total store energy<sup>[1]</sup>
- Compressor + condenser  $\approx 60 - 70\%$  refrigeration system<sup>[1]</sup>




[1] Baxter, V.D.: Advances in Supermarket Refrigeration Systems. IEA Annex 26 Summary. ORNL 2006

# Electricity Billing

- Kilowatt = rate of energy use
- Kilowatt-hour = quantity of energy used
- Electricity charge = [total kWh/month] \* \$/kWh
- Demand charge = [peak kW/month] \* \$/kW
- Ratchet: Demand = % \* [highest peak kW in last year] \* \$/kW


Energy cost = water used

Demand cost = bucket size



# Electricity Billing

- Kilowatt = rate of energy use
- Kilowatt-hour = quantity of energy used
- Electricity charge = [total kWh/month] \* \$/kWh
- Demand charge = [peak kW/month] \* \$/kW




Refrigerant

Air

# Conventional Air Cooled

Sensible heat transfer = temperature change




Refrigerant

Air

Water

# Conventional Evaporative

Latent heat transfer = phase change (evaporation)





Refrigerant

Air

Water


# Dry Coil Hybrid Condenser



Wet bulb and dry bulb temp  
Hybrid heat transfer  
High MBH/hp  
Small footprint  
No water treatment

# Condenser Types Summary

	<b>Air Cooled</b>	<b>Hybrid</b>	<b>Evaporative</b>
Ambient Heat Sink Temp	Dry Bulb	Dry Bulb AND Wet Bulb	Wet Bulb
Design Condensing Temp	105 – 120F	90 – 105F	90 – 105F
Efficiency	Lowest MBH/hp	High MBH/hp	Highest MBH/hp
Peak kW and Total kWh	Highest	Lower	Lowest
Footprint	Largest	Smaller	Smallest
Water Required	None	Water	Water + treatment








# Energy Analysis: Simple System

- Air Cooled vs Hybrid vs Evaporative Condensers
- R717 vs R407a
- TCO Summary

# Lund's Actual vs Estimated kW Savings (R407a)



■ Actual, with Air Cooled

130

230

■ Actual Saved with TrilliumSeries

35


110

■ Estimated Saved with TrilliumSeries Analysis


24

84


# Example: 150 Tons R717, +20F ST, Wash DC



# Example: 150 Tons R717, +20F ST, Wash DC



# 150 Tons R717, +20F ST, Wash DC



# Summary: R717

Total kWh/yr	Air Cooled	Hybrid	Evaporative
R717	844,467	738,549	694,775

Energy Savings →

13%

18%

Peak kW	Air Cooled	Hybrid	Evaporative
R717	219	149	128


Peak Demand Reduction →

32%

42%

\$0.12/kWh

# 150 TR System, +20F Suction, Washington DC




■ R-407A	932,561	866,251	842,786
■ R-717	844,467	738,549	694,775

System labels: Air Cooled, Hybrid, Evaporative

**\$11/kW Peak, 150 TR System, +20F Suction, Washington DC**


80% ratchet



	<b>Air Cooled</b>	<b>Hybrid</b>	<b>Evaporative</b>
R407a	227	171	152
R717	219	149	128




# Summary: Carbon Footprint



■ Direct CO2 Tons (Refrigerant)	99	0	11	0	139	0
■ Indirect CO2 Tons (Electricity)	448	406	416	355	405	334

# Total Cost of Ownership





Preston Blay, 410.799.6458, [pblay@baltimoreaircoil.com](mailto:pblay@baltimoreaircoil.com)  
Ilana Cember, 410.799.6238, [icember@baltimoreaircoil.com](mailto:icember@baltimoreaircoil.com)  
Please contact us to discuss your specific application.

