



AMERICA **ATMO**
sphere
business case
natural refrigerants

25 & 26 JUNE 2015, ATLANTA

**A desktop study into the
energy efficiency and
environmental benefits of
CO₂ refrigeration in USA
supermarkets**

By KLAAS VISSER Dip.Mar.Eng.

Hon M.IIR, M. Inst. R, M.IIAR, M.KNVvK, Meurammon

PRINCIPAL - KAV CONSULTING Pty. Ltd

P.O. BOX 1146, KANGAROO FLAT, Vic 3555 AUSTRALIA

Tel:- +61 3 54 479 436 Fax:- +61 3 54 474 896

Email: - kavconsult@bigpond.com


KAV CONSULTING **PTY LTD**
Advisers to the Refrigerated Food Industries

Profile of an Average U.S. Supermarket's Greenhouse Gas Impacts from Refrigeration Leaks Compared to Electricity Consumption



U.S. Supermarket Store Size	46,000 ft ²
Annual Electricity Consumption Intensity for U.S. Supermarkets	51 kWh/ft ²
Annual Electricity Consumed (Annual Consumption Intensity x Store Size)	2,346,000 kWh/year
Electricity Use Emission Factor (U.S. Average)	1.30 lbs of CO ₂ per kWh
Annual CO ₂ Emissions from Electricity Consumption	3,049,800 lbs of CO ₂ per year
Typical Commercial Refrigerant Used	R404A
Global Warming Potential (AR4 standard)	3,921.6
Commercial Refrigeration Charge Size	3,500 lbs
Annual Commercial Refrigeration Leak Rate	25% per year
Annual Volume of Commercial Refrigerant Leaked	875 lbs per year
Annual CO ₂ eq of R404A Leaked	3,431,400 lbs CO ₂ eq per year


Electricity



Annual Electrical Energy Consumption = 51 kWh/ft²
Annual Cost = \$5.31/ft² ≅ \$0.1041/kWh

© E Source – Data from the U.S. Energy Information Administration


Natural Gas



Annual Natural Gas Consumption = 41,000 BTUs/ft²
Annual Natural Gas Cost = \$0.38/ft² \equiv \$0.93/therm


© E Source – Data from the U.S. Energy Information Administration

Atlanta, Georgia, Usa Climate Graph (Altitude: 1033 ft)




Climate Variable	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
Average Max Temperature °C (°F)	10 (50)	13 (55)	18 (64)	23 (73)	26 (80)	30 (86)	31 (88)	31 (87)	28 (82)	23 (73)	17 (63)	12 (54)	22 (71)
Average Temperature °C (°F)	5 (41)	7 (45)	12 (53)	16 (62)	21 (69)	24 (76)	26 (79)	26 (78)	23 (73)	17 (62)	12 (53)	7 (44)	16 (61)
Average Min Temperature °C (°F)	0 (31)	1 (35)	6 (42)	10 (50)	15 (59)	19 (66)	21 (69)	21 (69)	18 (64)	11 (52)	6 (43)	2 (35)	11 (51)

Variation of COP with saturated suction temperature (SST) of various saturated condensing temperatures (SCTs) with air cooled condensing for a commercially available R404A compressor – 95cfm @ 50Hz.




Variation of COP with saturated condensing temperature (SCT) of various saturated suction temperatures (SSTs) for a commercially available CO₂ compressor – 40HP and 16 cfm @ 50Hz.



COP vs ambient & wet bulb for varying transcritical discharge pressures +5°C SST, 5 K SSH for chilled water AC and parallel compression.

Gas cooler exit temperature = Wet bulb temperature + 5.4°F (3K)



Source – Bock VAP10 Software

Summary of electrical energy consumed (EEC) by consumer and allocation to refrigeration, AC and heating plus evaluation of total emissions due to EE consumption and refrigerant (R404A) losses and annual EE cost

EE Consumer		EEC			Total Annual EEC & Emissions			
No	DESCRIPTION	% ⁽¹⁾	Unit	Qty	No	Parameter	=	Value ⁽²⁾
1	Refrigeration	57	kWh/ft ² annum	29.1	8	Store size, ft ²	=	46,000
2	Cooling (AC)	5		2.55	9	Total annual EEC, kWh	=	2,346,000
3	Space Heating	2		1.02	10	Total annual EE emissions, lbs	=	3,049,800
4	Water Heating	<u>1</u>		<u>0.51</u>	11	Total annual R404A emissions, lbs	=	3,431,400
5	Total cooling & heating	65		33.2	12	Total annual EE + R404A emissions, lbs	=	6,481,200
6	Other	<u>35</u>		<u>17.8</u>	13	Total annual EE cost @ \$5.31/ft ² (2)	=	244,260
7	Total	100		<u>51</u> ⁽¹⁾				

(1) From Slide 3

(2) From Slide 2

Analysis of electrical energy consumption (EEC) by consumer for refrigeration, AC, heating and cooling (RACHC) and evaluation of annual reduction in EEC in quantity and percentage in Atlanta

Parameter			EEC by Consumers and COP					
No	Description	Unit	Refrigeration			AC	Heat	Total
			Total	MT	LT			
1	Total energy consumption	kWh/ft ² /a	29.1	-	-	2.55	1.53	33.18
2	Estimated cond. and evap. EEC - fans, 10%	kWh/ft ² /a	2.91	-	-	0.26	-	3.17
3	Compressor EEC & Heating	kWh/ft ² /a	26.19	19.64 ⁽¹⁾	6.55 ⁽²⁾	2.29	1.53	30.01
4	COP existing systems. From Slide 6	-	-	2.75	1.47	3.84	1.0	-
5	Capacity = COP x EEC	kWR/ft ² /a	-	54.0	9.62	8.8	1.53	-
6	CO ₂ System COPs. From Slide 7	-	-	5.5 ⁽³⁾	2.44	7.4	0	-
7	CO ₂ energy = Cap. ÷ COP	kWh/ft ² /a	-	9.82	3.94	1.19	0	14.95
8	EEC reduction (3 – 7)	kWh/ft ² /a	-	9.82	2.61	1.10	1.53	15.06
9	Total annual EEC reduction in 46,000 ft ² store, 46,000 x 15.0 kWh with CO ₂ system						690,000	
10	EEC with R404A / CO ₂ system for RACH in 46,000 ft ² store, kWh						1,527,200 / 837,200	
11	EEC with R404A / CO ₂ system all consumers in 46,000 ft ² store @ 51kWh/ft ² , kWh ⁽⁴⁾						2,346,000 / 1,656,000	
12	Reduction in RACHC EEC, %						45.2%	
13	Reduction in store EEC over all consumers, %						29.4%	

- Notes:
- (1) 75% of refrigeration EEC by MT refrigeration
 - (2) 25% of refrigeration EEC by LT refrigeration
 - (3) Actual COP of 6.1 reduced by 10% to 5.5 to cover parallel compression during hot weather and heat pumping in cold weather
 - (4) From Slide 2

Summary of natural gas consumed by consumer, allocation of heat to space and water heating and annual cost

Natural Gas Consumed						
Parameter		%	BTUs/ft ² / annum	Derived Value		
No	NG Consumer			No	Parameter	Qty & Unit
1	Space heating	69	28,290	11	41,000 BTUs/ft ² /year ⁽²⁾	12 kWh
2	Water heating	<u>6</u>	<u>2,460</u>	12	To Heating	75%
3	Total heating	75	30,750	13	Then heat used/ft ² /year	9 kWh
4	Other – 88% cooking	<u>25</u>	<u>10,250</u>	14	Total gas heat/year	414,000 kWh
5	Total	100	<u>41,000</u>	15	Boiler efficiency 75%	75%
6	Store floor area, ft ² ⁽¹⁾		46,000	16	Gas heat used/ft ² /year	6.75 kWh
7	Total NG consumed, therms		18,860	17	Electric heat used/ft ² /year	1.53 kWh
8	Annual emissions, lbs		254,219	18	Total heat used/ft ² /year	8.28 kWh
9	Annual NG cost @ \$0.38/ft ²		\$17,480	19	Reduced annual NG cost	\$4,370.00
10	One (1) kWh		3,412 BTUs	20	Reduction in annual NG cost	\$13,110.00

Notes: ⁽¹⁾ From Slide 2

⁽²⁾ From Slide 4

Estimated Reduction in Annual CO₂ eq Emissions

No	Emission Source	Current CO ₂ emissions		CO ₂ Refrigeration and Heat Recovery		
		Unit	Quantity	Reduction in CO ₂ emissions		Estimated total CO ₂ emissions – lbs From all sources
				lbs	%	
1	EEC	lbs	3,049,800 ⁽¹⁾	897,000	29.4	2,152,800
2	NGC	lbs	254,219 ⁽²⁾	190,664	75	63,555
3	Refrigerant leaks (RL)	lbs	<u>3,431,400⁽¹⁾</u>	<u>3,430,525</u>	99.975	<u>875</u>
4	Total		<u>6,735,419</u>	<u>4,518,189</u>	<u>67.1</u>	<u>2,217,230</u>

Notes: (1) From Slide 3

(2) Calculated @ 13.48 lbs / therm

Estimated Reduction in Annual Utility & Refrigerant Costs


Cost Centre		Unit Name & Cost		Reduction in consumption		Present Annual Cost	Reduction in annual cost		
No	Description	Unit	\$	Unit	Quantity	\$	\$	%	
1	Electrical energy	kWh \$/ft ²	0.1041 5.31 ⁽¹⁾	kWh	690,000	244,260	71,829	29.4	
2	Natural gas	therm \$/ft ²	0.927 0.38 ⁽¹⁾	therms	14,145	17,480	13,110	75	
3	Refrigerant ⁽²⁾	Δ \$/lb	6-5=1	875 lbs	0	5,250	4,375	75	
4	Totals						266,990	89,314	33.5
5	Totals per square foot floor area						\$5.80	\$1.94	33.5
6	Say 90% realization then annual cost reduction							80,383	30.1

Notes: ⁽¹⁾ From Slide 3

⁽²⁾ 875 lb of refrigerant loss in both cases but CO₂ costs \$5 / lb less than R404A.

Technicians' time charges are assumed to be the same for each refrigerant. From Slide 2


Electricity



Annual Electrical Energy Consumption = 51 kWh/ft² - 36 kWh/ft² = 15kWh/ft² Saved
 Annual Cost = \$5.31/ft² ≅ \$0.1041/kWh CO₂ System \$3.75/ft² = \$1.56/ft² Saved

© E Source – Data from the U.S. Energy Information Administration

Natural Gas



Annual Natural Gas Consumption = 41,000 BTUs/ft² - 10,250 BTUs/ft² = 30,750 BTUs/ft² Saved
 Annual Natural Gas Cost = \$0.38/ft² ≡ \$0.93/therm CO₂ System \$0.095/ft² = \$0.285/ft² Saved

© E Source – Data from the U.S. Energy Information Administration

Refrigerant Heat Recovery

At one time, recovery and use of heat from refrigeration systems to provide space heating in grocery stores was used extensively and provided all or most of the heat in most stores across the US. However, refrigerant heat recovery has become less common in recent decades, largely to reduce refrigerant change and leakage. To reduce energy usage and operating costs and to meet sustainability objectives, many grocery chains are again considering refrigerant heat recovery.

California Title 24 Heat Recovery Requirements

California's 2013 Building Energy Efficiency Standards for Residential and Non-residential Buildings (Title 24) include mandatory requirements for commercial refrigeration and refrigeration heat recovery. Section 120.6(b) 4 requires that grocery stores use at least 25% of the heat from refrigeration for space heating in new stores (CEC 2013).

Source: ASHRAE et al. Advanced Energy Design Guide for Grocery Stores. Page 62. 3/18/2015